

# CERTIFICATE

Issued to:  
Applicant:  
**Eleqtron**  
**Energieweg 19**  
**3281 NH Numansdorp, The Netherlands**

Manufacturer/Licensee:  
**Müller Plastik GmbH**  
**Alte Bahnhofstrasse 21**  
**51688 Wipperfürth, Germany**

Product(s) : installation couplers  
Trade name(s) : Q  
Type(s)/model(s) : Q1ST-3P

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61535:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2018269

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 1 March 2013 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2161278.03

DEKRA Certification B.V.



drs. G.J. Zoetbrood  
Managing Director



H.L. Schendstok  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY  
THE DUTCH COUNCIL  
FOR ACCREDITATION



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	:	installation couplers
trade name	:	Q
type	:	Q1ST-3P
rated current	:	20 A
rated voltage	:	250 V~
design	:	male and female connector
earthing	:	with earthing contact
design	:	non-rewirable
applied flexible cord	:	H05VV-F 3G1,5 and 3G2,5 mm <sup>2</sup> H05V2V2-F 3G1,5 and 3G2,5 mm <sup>2</sup> H05Z1Z1-F 3G1,5 and 3G2,5 mm <sup>2</sup>
certification mark	:	complies with the requirements
cord termination	:	crimped connection
description	:	body of thermoplastic material as part of an incomplete or complete cord set for class I appliances
markings	:	are shown on the body

**TESTS****Test requirements**

EN 61535:2009

**Test result**

The test results are laid down in DEKRA test file 2161278.03.

**Remarks**

This certificate replaces our certificate 2156782.03 dated 20120-09-20 and is also based on our certificate 2161278.03.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : H.R.M. Barends



Checked by : M.A.R. Bollen



**Factory locations**

Müller Plastik GmbH  
Alte Bahnhofstrasse 21, 51688, Wipperfürth  
Germany