DATASHEET - TM-1-8240/EZ



Step switches, Contacts: 2, 10 A, front plate: 0-1-2, 60 °, 2 steps, 60°, maintained, centre mounting



Part no. TM-1-8240/EZ Catalog No. 015226

EL-Nummer (Norway) 0001456168

Delivery program

Delivery program			
Product range			Control switches
Part group reference			TM
Basic function			Step switches
			with black thumb grip and front plate
Contacts			2
Number of steps			2 steps, 60°
Degree of Protection			Front IP65
Design			centre mounting
Contact sequence			10 200 300 400 X
Switching angle		o	60
Switching performance			maintained With 0 (Off) position
Design number			8240
Front plate no.			$ \begin{bmatrix} 1 & 2 \\ 0 & 8 \end{bmatrix} $ F 075
front plate			0-1-2
Motor rating AC-23A, 50 - 60 Hz			
400 V	Р	kW	3
Rated uninterrupted current	l _u	Α	10
Note on rated uninterrupted current !u			Rated uninterrupted current $\mathbf{I}_{\mathbf{U}}$ is specified for max. cross-section.
Number of contact units		contact unit(s)	1

Technical data

Genera

delleral	
Standards	IEC/EN 60947, VDE 0660, CSA, UL Control switch as per IEC/EN 60947-5-1 Auxiliary switch as per IEC/EN 60947-5-1
Climatic proofing	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ambient temperature	

	°C	-25 - +50
		III/3
Uimp	V AC	4000
Сппр		As required
		As required
U _e	V AC	500
l _u	Α	10
		Rated uninterrupted current I _u is specified for max. cross-section.
	A aG/al	10
	71 go/gE	10
	W	0.15
	CO	0.15
Operations	v 10 ⁶	>1
	X IU	
орегация (п		1200
P	k\M	
		3
probability	''F	< 10 ⁻⁵ , < 1 fault in 100000 operations
	mm^2	1 x 1,5 2 x 1,5
	2	1 x 1.0
	mm ⁻	2 x 1.0
	mm^2	1 x 1.5
		2 x 1.5 M2.5
	Nm	0.4
	IVIII	0.4
U _e	V AC	300
	Α	10
lu	Α	10
		A 300
	НР	0.33
	НР	0.75
	НР	0.75
	НР	0.75
	НР	1
	AWG	14
		M2.5
		3.5
	Operations Operations/h P P Fault	Ue VAC Iu A A gG/gL W CO Operations x 106 Operations/h P kW P kW Fault probability

Design verification as per IEC/EN 61439

Technical data for design verification

Rated operational current for specified heat dissipation	In	Α	10
Heat dissipation per pole, current-dependent	P _{vid}	W	0.15
Equipment heat dissipation, current-dependent	P _{vid}	W	0
Static heat dissipation, non-current-dependent	P _{vs}	W	0
Heat dissipation capacity	P _{diss}	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	50
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			UV resistance only in connection with protective shield.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Control switch (EC002611)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Control switch (ecl@ss10.0.1-27-37-14-14


Type of switch Level switch Number of poles 1 Max. rated operation voltage Ue AC V 500 Rated permanent current lu Image: Control of Switch positions 3 With 0 (off) position Yes Yes With retraction in 0-position Image: Control of Switch position No Device construction Switch position No With in number of modular spacings Switch position No Suitable for ground mounting No Yes Suitable for front mounting 4-hole Yes No Suitable for distribution board installation No No Suitable for intermediate mounting No No Complete device in housing No No Type of control element Type of control element No Type of control element Front shield size Swiss David No No	[ACN998011])		
Max. rated operation voltage Ue AC Rated permanent current lu Number of switch positions With 0 (off) position With retraction in 0-position No Device construction Device construction Width in number of modular spacings With programment current lu No Suitable for ground mounting Suitable for front mounting 4-hole Suitable for distribution board installation Suitable for intermediate mounting Complete device in housing Type of control element No Toggle	Type of switch		Level switch
Rated permanent current lu Number of switch positions With 0 (off) position With retraction in 0-position With retraction in 0-position Device construction Width in number of modular spacings With provide for ground mounting Suitable for ground mounting Suitable for front mounting 4-hole Suitable for intermediate mounting Suitable for intermediate mounting Complete device in housing Type of control element A 10 10 A 10 A	Number of poles		1
Number of switch positions With 0 (off) position With 0 (off) position With retraction in 0-position No Device construction Width in number of modular spacings Suitable for ground mounting Suitable for front mounting 4-hole Suitable for distribution board installation Suitable for intermediate mounting Suitable for intermediate mounting No Complete device in housing Type of control element Suitable for control element Suitable for control element Suitable for intermediate mounting No Toggle	Max. rated operation voltage Ue AC	V	500
With 0 (off) position With 10 (off) position No Device construction Width in number of modular spacings With before ground mounting Suitable for ground mounting Suitable for distribution board installation Suitable for intermediate mounting Complete device in housing Type of control element Yes Toggle	Rated permanent current lu	А	10
With retraction in 0-position Device construction Width in number of modular spacings Width in number of modular spacings Suitable for ground mounting Suitable for front mounting 4-hole Suitable for distribution board installation Suitable for intermediate mounting Complete device in housing Type of control element No No No Toggle	Number of switch positions		3
Device construction Built-in device Width in number of modular spacings 0 Suitable for ground mounting No Suitable for front mounting 4-hole Yes Suitable for distribution board installation No Suitable for intermediate mounting No Complete device in housing Type of control element Built-in device No No Toggle	With 0 (off) position		Yes
Width in number of modular spacings 0 Suitable for ground mounting No Suitable for front mounting 4-hole Suitable for distribution board installation No Suitable for intermediate mounting No Complete device in housing No Type of control element 0 0 No Toggle	With retraction in 0-position		No
Suitable for ground mounting Suitable for front mounting 4-hole Yes Suitable for distribution board installation Suitable for intermediate mounting Complete device in housing Type of control element No Toggle	Device construction		Built-in device
Suitable for front mounting 4-hole Suitable for distribution board installation Suitable for intermediate mounting No Complete device in housing Type of control element Yes No No Toggle	Width in number of modular spacings		0
Suitable for distribution board installation Suitable for intermediate mounting No Complete device in housing No Type of control element No Toggle	Suitable for ground mounting		No
Suitable for intermediate mounting No Complete device in housing No Type of control element Toggle	Suitable for front mounting 4-hole		Yes
Complete device in housing No Type of control element Toggle	Suitable for distribution board installation		No
Type of control element Toggle	Suitable for intermediate mounting		No
	Complete device in housing		No
Front shield size 30x30 mm	Type of control element		Toggle
	Front shield size		30x30 mm


Degree of protection (IP), front side	IP65	
Degree of protection (NEMA), front side	Other	


Approvals

Product Standards	UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94; IEC/EN 60947-3; CE marking
UL File No.	E36332
UL Category Control No.	NLRV
CSA File No.	UL report applies to both US and Canada
North America Certification	UL listed, certified by UL for use in Canada
Degree of Protection	IEC: IP65; UL/CSA Type: –

Dimensions







Door drilling dimensions Drilling dimensions: either 16.2 mm = without reduction \triangle RMQ16 or 22.3 mm = with reduction \triangle RMQ Titan

Assets (links)

Declaration of CE Conformity

00002932

Instruction Leaflets

IL03801026Z2018_04