## **DATASHEET - BBA2-63**



Busbar adapter, 72mm, 63A, 1TS

Part no. BBA2-63 Catalog No. 101458 Alternate Catalog BBA2-63

No.

EL-Nummer 2465053

(Norway)



**Delivery program** 

| Accessories               |                |          | Busbar adapters  |
|---------------------------|----------------|----------|--|
|                           |                |          | Approved to UL 508 For fitting to flat Cu-busbars with 60 mm between busbar centres, suitable for 5 mm and 10 mm busbar thickness Rated operational current 63 A For motor-protective circuit-breakers |
| For use with              |                |          | Busbar adapters PKZ2   |
| Rated operational voltage | U <sub>e</sub> | V        | 690  |
| Rated operational current | Ie             | Α        | 63   |
| Terminal capacity         |                |          | AWG 8 (10 mm <sup>2</sup> )  |
| Adapter width             |                | mm       | 72   |
| Adapter length            |                | mm       | 200  |
| DIN rail                  |                | Quantity | 1  |
| Adapter width             |                | mm       | 72   |
| For use with              |                |          | PKZM4, PKE65   |

### Design verification as per IEC/EN 61439

| Design vernication as per IEG/EN 01439   |                   |    |  |
|--|-------------------|----|--|
| Technical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 63   |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 6.9  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 55   |
| IEC/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.                         |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.                         |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.                         |
| $10.2.3.3\ Verification\ of\ resistance\ of\ insulating\ materials\ to\ abnormal\ heat\ and\ fire\ due\ to\ internal\ electric\ effects$ |                   |    | Meets the product standard's requirements.                         |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.                         |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.                         |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.                         |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.                             |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.                             |
| 10.9 Insulation properties   |                   |    |  |

| 10.9.2 Power-frequency electric strength                 | Is the panel builder's responsibility.   |
|--|--|
| 10.9.3 Impulse withstand voltage                         | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility.   |
| 10.10 Temperature rise                                   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating                               | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility                      | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function                                | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Busbar adapter (EC001531)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Busbar trunking system (LV circuitry) / Busbar adapter (low-voltage switching technology) (ecl@ss10.0.1-27-37-03-04 [ACN951011])


| Mounting rail armament      |   |    | 1 mounting rail |
|-----------------------------|---|----|-----------------|
| Type of electric connection |   |    | Round conductor |
| Rated current In            | А | ١  | 63              |
| Min. busbar thickness       | m | nm | 5               |
| Max. busbar thickness       | m | nm | 10              |
| Width of the adapter        | m | nm | 72              |
| Rail width                  | m | nm | 35              |
| Busbar distance             | m | nm | 60              |

#### **Approvals**

| Product Standards                    | UL 508A; CSA-C22.2 No. 14; IEC60439-1; CE marking |
|--------------------------------------|---|
| UL File No.                          | E300273   |
| UL Category Control No.              | NMTR; NMTR7                                       |
| North America Certification          | UL listed, certified by UL for use in Canada      |
| Specially designed for North America | No  |
| Max. Voltage Rating                  | 600 V AC  |

# Dimensions





#### **Assets (links)**

**Instruction Leaflets** 

IL03402015Z2018\_05