





## RF Radiator Thermostat CHVZ-01/05

M30 x 1,5 mm



### Adapters included



### RF Radiator Thermostat Thread


CHVZ-00/05 M30 x 1,5 mm

Adapters	Type	Thread
CMMZ-00/41	Herz	M28 x 1,5 mm
CMMZ-00/42	TA	M28 x 1,5 mm
CMMZ-00/43	Comap	M28 x 1,5 mm
CMMZ-00/44	Markaryds	M28 x 1,5 mm



### Technical Data / Technische gegevens / Tekniske data / Technische Daten / Technická data


Power supply	3V battery (2 x 1.5 V LR6/Mignon/AA)
Battery lifetime	2 years (TYP)
Connection	M30 x 1,5 mm Heimeier, Junkers Landy + Gyr, MNG, Honeywell-Braukmann, Oventrop, Schlösser, Sipmolex, Valf Sanayii, Metrik Maxitrol, Watts, Wingenroth (Wiroflex), R.B.M., Jaga, Siemens, Idmar)
Included Adapter	Danfoss RAV 34mm + pin, Danfoss RA 20mm or 23mm, Danfoss RAVL 26mm
Available Adapters	Herz, Comap, markaryds, RA (Tour & Andersson)
Radio Frequency	868,3 MHz (xComfort compatible)
Weight (incl. batteries)	176g
Degree of protection	IP20
Degree of pollution	2
Output Power	+4dBm
Dimensions	56 x 68 x 89 mm (H x W x D)










**MRF** Version V2.53

**RM** Version V41c  
**SHC-RF** Version 2.20  
**ECl-RF** Version 2.10  
**USB-RF** Version: 2.10






Valve type	Thread	Adapter	Code	Article
Heimeier, Junkers Landy + Gyr, MNG, Honeywell-Braukmann, Oventrop, Schlösser, Simplex, Valf Sanayii, Metrik Maxitrol, Watts, Wingenroth (Wiroflex), R.B.M., Jaga, Siemens, Idmar	M30 x 1,5 mm	<b>X</b>	Not needed	-
Danfoss RA	20 mm or 23 mm		Included	-
Danfoss RAV	34 mm + pin		Included	-
Danfoss RAVL	26 mm		Included	-
Herz	M28 x 1,5		700 100 004	CMMZ-00/41
TA (Tour & Andersson)	M28 x 1,5		700 100 006	CMMZ-00/42
Comap	M28 x 1,5		700 100 007	CMMZ-00/43
Markaryds	M28 x 1,5		700 100 010	CMMZ-00/44



7.



8.




Error: JIN, ER1-ER3

Disassemble radiator thermostat, remove batteries and reinstall from step 1  
 Demonteer thermostaatkraan, verwijder de batterijen en installeer opnieuw vanaf stap 1  
 Heizkörperthermostat demontieren, Batterien entnehmen und ab Schritt 1 neu installieren  
 Demontér radiatortermostaten, fjern batteriene og installer på nytt fra trinn 1  
 Rozeberte radiátorový termostat, vyjméte baterie a znovu nainstalujte podle kroku 1

## Operation / Werking / Betrieb / Drift / Ovládání

### Display elements / Display-elementen /

### Anzeigeelemente / Visingselementer / Symboly na displeji



Installation in progress / Installatie is bezig / Installation läuft /  
 Installasjon pågår / Instalace v běhu



xComfort Connection OK / xComfort-verbinding OK / xComfort  
 Verbinding OK / xComfort tilkobling OK / xComfort spojení OK  
 Off: No connection / Uit: geen verbinding / Aus: Keine Verbindung /  
 Av: ingen tilkobling / Nezobrazeno: Žádné spojení  
 Blinking: Connection failure / Knipperend: verbindingfout / Blink:  
 Verbindingsfehler / Blinker: Tilkoblingsfeil / Blikání: Chyba spojení



Local Mode / Lokale modus / Lokalbetrieb / Lokal drift / Lokální mód



Battery <15% / Batterij <15% / Batterie <15% / Batteri <15% / Baterie <15%



Child protected / Kinderslot / Kind geschützt / Barnesikret / Dětská pojistka



Temperature Setpoint / Temperatuur setpoint / Temperatursollwert /  
 Temperatur settpunkt / Nastavení požadované teploty

### Control buttons / Bedieningsknoppen / Bedientasten / Betjeningsknapper / Ovládací tlačítka



Increase setpoint / Verhoog setpoint / Sollwert erhöhen / Øk settpunkt /  
 Zvýšit požadovanou teplotu




Decrease setpoint / Verlaag setpoint / Sollwert verringern / Reduser settpunkt /  
 Snížít požadovanou teplotu



Backlight / Achtergrondverlichting / Hintergrundbeleuchtung / Bakgrunnsllys / Podsvícení  
 (>2s: Send Notification / Notificatie /  
 Benachrichtigung /  
 send varsel / Odeslat data)



or Controller  
 of Controller  
 oder Controller  
 eller Controller  
 nebo řídící jednotka



>3s: Enable/disable child protection / Kinderslot In-/Uitschakelen / Kinderschutz Aktivieren /  
 Deaktivieren / Aktivere/deaktivere barnesikring / Povolit/zakázat dětskou pojistku



