# DATASHEET - SDAINLM70(230V50HZ,240V60HZ)



Star-delta contactor combination, 380 V 400 V: 37 kW, 230 V 50 Hz, 240 V 60 Hz, AC operation



Powering Business Worldwide

Part no. SDAINLM70(230V50HZ,240V60HZ)

Catalog No. 239895

Alternate Catalog XTSD070D11F


No.

**EL-Nummer** 4131005

(Norway)

#### **Delivery program**

		Contactor combinations
		Star-delta motor starting for contactor combinations
		Star-delta combinations SDAINL
		NAC-3: Normal AC induction motors: starting, switch off during running
		IE3 ✓
		Also suitable for motors with efficiency class IE3. IE3-ready devices are identified by the logo on their packaging.
		Operating frequency: maximum 30 starts per hour
I <sub>e</sub>	Α	70
P	kW	18.5
P	kW	37
P	kW	45
P	kW	37
	S	20
		230 V 50 Hz, 240 V 60 Hz
		AC operation
	Part no.	DILM40 + DILM150-XHI31
	Part no.	DILM40 + DILM150-XHI11
	Part no.	DILM40 + DILM150-XHI11
	Part no.	ETR4-51
	P P P	P kW P kW P kW S P art no. Part no.



Q11

# **Design verification as per IEC/EN 61439**

Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	70
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	6.7
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	20
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	10.2


Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	60
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
$10.2.3.3\ Verification\ of\ resistance\ of\ insulating\ materials\ to\ abnormal\ heat\ and\ fire\ due\ to\ internal\ electric\ effects$			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:specification}$
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

### **Technical data ETIM 7.0**


Low-voltage industrial components (EG000017) / Combination of contactors (EC000010)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Contactor (LV) / Combination of contactor (ecl@ss10.0.1-27-37-10-09 [AGZ572014]

Electric engineering, automation, process control engineering / Low-voltage switch technology / Contactor (LV) / Combination of contactor (ecl@ss10.0.1-27-37-10-09 [AGZ572014])				
Function			Star-delta contactor	
Rated control supply voltage Us at AC 50HZ		V	230 - 230	
Rated control supply voltage Us at AC 60HZ		V	240 - 240	
Rated control supply voltage Us at DC		V	0 - 0	
Voltage type for actuating			AC	
Rated operation current le at AC-3, 400 V		Α	70	
Rated operation power at AC-3, 400 V		kW	37	
Rated operation power NEMA		kW	0	
Type of electrical connection of main circuit			Screw connection	
Degree of protection (IP)			IP00	
Degree of protection (NEMA)			Other	



### **Dimensions**



# Assets (links)

**Declaration of CE Conformity** 

00003252

**Instruction Leaflets** 

IL03407030Z2018\_05 IL03407033Z2018\_03