# DATASHEET - M22-PVS/K01



### Emergency switching off key-operated button, 1 N/C, front mount



M22-PVS/K01 Part no. Catalog No. 216514

Alternate Catalog M22-PVS-K01Q

No.

	EL-Nummer (Norway)	4355287			
<b>Delivery program</b>	<u> </u>				
Product range					RMQ-Titan
Basic function					Controlled stop pushbuttons/emergency-stop buttons
Single unit/Complete unit					Complete unit
Design					Mushroom-shaped
Diameter			Ø	mm	38
Illumination					Non-illuminated
Approval					ET 16107 Sicherheit geprüft tested safety  Key-release
Connection time					
Connection type					Screw connection
Description					Tamper-proof according to ISO 13850/EN 418
0.1					Not suitable for master key systems
Colour  Mushroom head					Red
Base					yellow RAL 3000
Degree of Protection					IP66, IP67, IP69
Connection to SmartWire-DT					no
Contacts					
N/C = Normally closed					1 NC →
Notes					= safety function, by positive opening to IEC/EN 60947-5-1
Actuator travel and actua K.5.4.1	tion force as per DIN E	N 60947-5-1,			
			mm		4.8
Maximum travel			mm		5.7
Minimum force for positive op	pening		N		15
Contact sequence					
Front dimensions					35
Instructions					Max. number of contacts: four M22-(C)K01,10 or two M22-(C)K02,20,11

### **Technical data**

#### General

ciiciai			
andards			IEC/EN 60947 VDE 0660
fespan, mechanical	Operations	x 10 <sup>6</sup>	> 0.1
perating frequency	Operations/h		≦ 500
ctuating force		n	≦ 50
imatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
egree of Protection			IP66, IP67, IP69
mbient temperature			
Open		°C	-25 - +70
ounting position			As required
lechanical shock resistance		g	50 Shock duration 11 ms Sinusoidal according to IEC 60068-2-27
nipping classification			DNV GL LR
			Lloyd's Register  TYPE APPROVED
ontacts			

kA

## **Design verification as per IEC/EN 61439**

Rated conditional short-circuit current

Design verification as per IEC/EN 61439			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	6
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0.11
Equipment heat dissipation, current-dependent	$P_{vid}$	W	0
Static heat dissipation, non-current-dependent	$P_{vs}$	W	0
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.		°C	-25
Operating ambient temperature max.		°C	70
EC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Please enquire
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.

10.9 Insulation properties	
10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
10.10 Temperature rise	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

#### **Technical data ETIM 7.0**


Low-voltage industrial components (EG000017) / Emergency stop complete (EC002034)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / EMERGENCY-STOP pushbutton, complete device (ecl@ss10.0.1-27-37-12-44 [ACN986011])

Unlocking method		Key-release
Number of contacts as normally closed contact		1
Number of contacts as normally open contact		0
Degree of protection (IP)		IP67/IP69K
Mounting method		Built-in
With lighting		No
Hole diameter	mm	22
Connection type auxiliary circuit		Screw connection
Diameter cap	mm	38

# Approvals

Product Standards	IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	012528
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified
Degree of Protection	UL/CSA Type 3R, 4X, 12, 13





## Assets (links)

**Declaration of CE Conformity** 00003256