borsan kablo®

DECLARATION of PERFORMANCE

Number : **BR-135**

1. Unique identification code of the product:

H05Z-K

Damar Sayısı	Kesit (mm²)
1	0.5 - 0.75 - 1

Classification Report Number : 3130-CPR-194

2. Intended use of the product :

It is used in hotels, schools, high buildings, hospitals, data processing centers and crowded business centers and fi re-sensitive areas.

3. Manufacturer:

BORSAN Kablo Elektrik Aydınlatma İnş. ve Tic. A.Ş Şabanoğlu OSB Mah. Organize Sanayi Bulv. No:40/1 Tekkeköy/Samsun / TURKEY

4. System of assessment and verification of constancy of performance of the product

System 1+

The range of cables described in 1&2 belongs to Euroclass Cca-s1a,d2,a1

Euroclass Cca-s1a,d2,a1 equals to System 1+

5. Notified Body: **NB 3130**

6. Declared Performance

Essential characteristics	Performance	Harmonized Technical Specification
Reaction to fire	**Cca-s1a,d2,a1**	**EN 50575:2014 + A1: 2016**
Dangerous substances	**None**	

7. The performance of the product defined is suitable for the performance declared in Article 6.

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and in name of the manufacturer by:

Product Development Manager: ***Ekrem ALTAN***

14.09.2026

BORSAN KABLO ELEKTRİK AYDINLATMA İNŞ.SAN.TİC.A.Ş. Organize Sanayi Bulvarı No:40/1 Tekkeköy / SAMSUN 19 Mayıs V.D. Vergi No:1800442731

Borsan Kablo Elektrik Aydınlatma Aş.

Bakır Fabrika/Copper Factory
OSB Organize Sanayi Bulvarı
No: 40-1
Tekkeköy / Samsun
T: +90 (362) 266 5925
F: +90 (362) 266 6194
E-mail: borsan@borsan.com.tr
E-posta: export@borsan.com.tr

Alüminyum Fabrika/Aluminum Factory
OSB Vali M. Erdoğan Cebeci Bulvarı No: 54
Tekkeköy / Samsun
T: +90 (362) 266 9914
F: +90 (362) 266 9989
E-mail: borsan@borsan.com.tr
E-posta: export@borsan.com.tr